

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7150-1496:161 Page 1 of 1

**CATEGORY:** Boxes/Pull Stations

**LISTEE:** Firecom, Inc., 39-27 59<sup>th</sup> Street, Woodside, NY, 11377  
Contact: Howard Kogen (718) 899-6100

**DESIGN:** Model FCMS-95 analog/addressable, noncoded, manual pull station. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** Primary Operating Supply: 21 VDC, 1.4 mA Max.

**INSTALLATION:** In accordance with listee's printed installation instructions and applicable codes and ordinances. May be installed in a listed outlet box or listee's backbox.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as manual pull station for use with listee's separately listed compatible fire alarm control units. For indoor use only.

**XLF:** 7150-1288:148

05-25-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**APRIL 22, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager